



12150 Luther Road • Auburn, CA 95603-3495



WELL DRILLING • PUMPS • SERVICE

WELL PRODUCTION TEST

DATE OF TEST: July 29, 2011

AT THE REQUEST OF: Boy Scouts of America Golden Empire

COUNTY - APN: El Dorado County - APN #096-080-04-100

PROPERTY LOCATION/ADDRESS: 2200 Camp Nauvoo Road
Placerville CA 95667-8441

WELL & PUMP SYSTEM:

DEPTH OF WELL: UNKNOWN

STATIC WATER LEVEL: UNKNOWN

WELL CASING/DROP PIPE SIZE: 6" PVC Well Casing with 1-1/4" drop pipe

PUMP/CONTROL BOX SIZE: 3-HP Franklin Control Box present

PRESSURE TANK: Two 119-Gallon Challenger Pressure Tanks present

STORAGE TANK: NONE

Storage Tank Booster Pump: NONE

ADDITIONAL SYSTEM(S): NONE

Filtration/Softener/Neutralizer/Etc. NONE

BACTERIA SAMPLE TAKEN: YES


GENERAL CONDITION OF THE WELL: Although well appears in good condition, one of the two 119-Gallon Pressure Tanks is failed and should be replaced (tank located in the front of door is failed).

A FOUR HOUR PUMP TEST HAS BEEN PERFORMED

THE MINIMUM WELL PRODUCTIC 27+ (Twenty Seven Plus) GALLONS PER MINUTE

NOTE: THE FLOW RATE REFLECTS THE OUTPUT OF THE WELL AT THE TIME OF THIS PUMP TEST ONLY. GARY C. TANKO WELL DRILLING, INC. IS HELD HARMLESS SHOULD THE OUTPUT OF THE WELL VARY IN THE FUTURE.

TEST PERFORMED BY: GARY C. TANKO WELL DRILLING, INC.



Anthony F. Segarra - Vice President

STATE LICENSE NO: 282051