

RE: Meeting w/ County Fire District (7/21/11, 10am)

We met on-site with El Dorado Deputy Fire Marshall, Mike Potts.

He surveyed the property for approximately 30 minutes and made the following recommendations (not requirements).

- Improve the turn outs on entrance road. We counted 14 areas where vehicles could pass. They suggested cleaning them up and making them more recognizable.
- Upgrade hood system in the kitchen to a newer version (FM 300). This is suggested only if we plan to do a lot of cooking.
- Recertify fire extinguishers and install at a lower level
- Extend and add a few more stand pipes for the fire water (i.e. install stand pipe closer to parking lot; easier access for fire trucks).
- New construction of buildings over 3,600 square feet requires a sprinkler system. Any residence would also require sprinkler system.
- Install 5-10,000 gallon water tank

Everything else looked good. They were very impressed with the site.